
To: Cindy Walden
Subject: RE: AUDIO AND RECOMMENDATIONS FROM THE JUNE 20, 2011 RULE HEARING

From: Info Fpat [<mailto:info@fpataadjusters.com>]
Sent: Friday, July 08, 2011 12:38 PM
To: Cindy Walden
Subject: RE: AUDIO AND RECOMMENDATIONS FROM THE JUNE 20, 2011 RULE HEARING

Millions of condominium unit owners and HOA unit owners use the OIR1802

Roof Covering:

Predominant. How much of the roof covering must be new. This should be spelled out in the header Example Mansard with new flat portion and old mansard portion
Mechanical Equipment must be installed to code.

Roof Deck Attachment:

Add steel bar joist with pans and lightweight conc., gypsum panels, etc.

Roof Wall Attachment:

Must specify the amount of nails used in a clip!!
Add steel bar joists welded or embedded in masonry wall.

Roof Geometry:

Do gable dormers count?
Eliminate major wall length terminology! Very confusing be more specific if roof has flat sections. The flat sections must be less than 10% of total building perimeter.

Sum of all gable ends versus total building perimeter. Gable ends must not exceed 10% of total building perimeter
Flat roof area versus total building perimeter area. Flat roof area must not exceed 10% of area.

Thank you,

Phillip E. Franco



PO Box 3977
Spring Hill, FL 34611
Phone 866.568.7853 or 727.388.9006
Fax 866.804-1052 or 727.388.4434
Email info@fpatadjusters.com
URL www.fpatadjusters.com



Please consider the environment before printing this email.

MAKE YOUR BUSY DAY EASIER! JUST [CLICK HERE](#) TO REQUEST YOUR NEXT PROPOSAL ONLINE.

From: Cindy Walden [<mailto:cindy.walden@flor.com>]
Sent: Wednesday, July 06, 2011 9:20 AM
Subject: AUDIO AND RECOMMENDATIONS FROM THE JUNE 20, 2011 RULE HEARING

Following is the link for the audio, comments/recommendations, and other documentation for the OIR-B1-1802 Uniform Mitigation Verification Inspection Form rule hearing held June 20, 2011. Comments will be added as received and the deadline to submit recommendations to the Office will be **Friday, July 8, 2011, 5 p.m.** If you have any questions, please let me know.

<http://www.flor.com/Sections/PandC/ProductReview/UniformMitigationForm.aspx>

Cindy Walden
Government Analyst I
Office of Insurance Regulation
Property & Casualty Product Review
(850) 413-2616 (Phone)
(850) 922-3865 (Fax)
Cindy.Walden@flor.com